

Dataset Expocode	32DB20180327
Primary Contact	Name: Stacy Maenner Jones Organization: NOAA/PMEL Address: 7600 Sand Point Way NE Seattle, WA 98115-6349 Phone: 206-526-6247 Email: Stacy.Maenner@noaa.gov
Investigator	Name: Dr. Adrienne Sutton Organization: NOAA/PMEL Address: 7600 Sand Point Way NE Seattle, WA 98115-6349 Phone: (206) 526-6879 Email: Adrienne.Sutton@noaa.gov
Investigator	Name: Dr.Bronte Tilbrook Organization: CSIRO Oceans and Atmosphere Address: Castray Esplanade, Hobart, Tasmania 7001 Australia Phone: +61 407 688832 Email: bronte.tilbrook@csiro.au
Dataset	Funding Info: NOAA Initial Submission (yyyymmdd): 01/26/2020 Revised Submission (yyyymmdd):
Campaign/Cruise	Expocode: 32DB20180327 Campaign/Cruise Name: Campaign/Cruise Info: Platform Type: CO2 Instrument Type: Survey Type: Autonomous Surface Vehicle, Saildrone Vessel Name: Vessel Owner: Vessel Code: 32DB
Coverage	Start Date (yyyymmdd): 20180327 End Date (yyyymmdd): 20180422 Westernmost Longitude: 147.2883 E Easternmost Longitude: 150.6503 E Northernmost Latitude: 42.5005 S Southernmost Latitude: 53.5874 S
Variable	Name: Date Time Unit: Description: Date and Time (UTC)
Variable	Name: xCO2 SW (wet) Unit: Description: (umol/mol) Mole fraction of CO2 in air in equilibrium with the seawater at sea surface temperature and measured humidity.
Variable	Name: CO2 SW QF Unit: Description: Flag for xCO2 sw (wet)
Variable	Name: H2O SW Unit: Description: (mmol/mol) Mole fraction of H2O in air from equilibrator.

Variable	Name: xCO2 Air (wet) Unit: Description: umol/mol) Mole fraction of CO2 in air from airblock, 2 feet above the sea surface at measured humidity.
Variable	Name: CO2 Air QF Unit: Description: Quality Flag for xCO2 Air (wet)
Variable	Name: H2O Air Unit: Description: (mmol/mol) Mole fraction of H2O in air from airblock, 2 feet above the sea surface.
Variable	Name: Licor Atm Pressure Unit: Description: (hPa) Atmospheric pressure at the airblock, 2 feet above the sea surface.
Variable	Name: Licor Temp Unit: Description: (C) Temperature of the Infrared Licor 820 in degrees Celsius.
Variable	Name: MAPCO2 %O2 Unit: Description: The percent oxygen of the surface seawater divided by the percent oxygen of the atmosphere at 2 feet above the sea surface. Disclaimer: The oxygen measurement is made in the equilibrated air. We have found that the oxygen does not come to complete equilibrium so any rapid changes in oxygen do not get properly captured using this system. Therefore, we tend to use the oxygen data only as a qualitative sense of the biology. It is not a quantitative measure.
Variable	Name: SST Unit: Description: (C) Sea Surface Temperature.
Variable	Name: Salinity Unit: Description: (PSU) Sea Surface Salinity.
Variable	Name: xCO2 SW (dry) Unit: Description: (umol/mol) Mole fraction of CO2 in air in equilibrium with the seawater at sea surface temperature (dry air).
Variable	Name: xCO2 Air (dry) Unit: Description: (umol/mol) Mole fraction of CO2 in air at the airblock, 2 feet above the sea surface (dry air).
Variable	Name: fCO2 SW (sat) Unit: Description: (uatm) Fugacity of CO2 in air in equilibrium with the seawater at sea surface temperature (100% humidity). Since the measurements are taken at the sea surface, warming calculations are not necessary.
Variable	Name: fCO2 Air (sat) Unit:

Description: (uatm) Fugacity of CO₂ in air at the airblock, 2 feet above the sea surface (100% humidity).

Variable

Name: dfCO₂

Unit:

Description: Difference of the fugacity of the CO₂ in seawater and the fugacity of the CO₂ in air (fCO₂ SW - fCO₂ Air).

Variable

Name: pCO₂ SW (wet)

Unit:

Description: (uatm) Partial Pressure of CO₂ in air in equilibrium with the seawater at sea surface temperature (100% humidity)

Variable

Name: pCO₂ Air (wet)

Unit:

Description: (uatm) Partial Pressure of CO₂ in air at the airblock, 2 feet above the sea surface (100% humidity).

Variable

Name: dpCO₂

Unit:

Description: Difference of the partial pressure of CO₂ in seawater and air (pCO₂ SW - pCO₂ Air)

Variable

Name: pH SW

Unit:

Description: pH of Seawater (total scale)

Variable

Name: pH QF

Unit:

Description: Quality Flag for pH

**Sea Surface
Temperature**

Location: 0.5m

Manufacturer: SeaBird

Model: SBE37 modified for compact deployments

Accuracy: < 0.01 (°C if units not given)

Precision: (°C if units not given)

Calibration: ~ Annually by SeaBird

Comments: Temperature data are internally recorded and collected during the equilibration period. Data are not post-calibrated. Annual drift for this deployment was minimal and does not impact the fCO₂ and pCO₂ calculations (within the degree of accuracy of the CO₂ measurement). Contact us if you would like the CTD post-calibration information.

Sea Surface Salinity

Location: 0.5m

Manufacturer: SeaBird

Model: SBE37 modified for compact deployments

Accuracy: < 0.05

Precision:

Calibration: ~ Annually by SeaBird

Comments: Conductivity data are internally recorded and collected during the equilibration period. Data are not post-calibrated. Annual drift for this deployment was minimal and does not impact the fCO₂ and pCO₂ calculations (within the degree of accuracy of the CO₂ measurement). Contact us if you would like the CTD post-calibration information.

**Atmospheric
Pressure**

Location:

Normalized to Sea Level:

Manufacturer:
Model:
Accuracy: (hPa if units not given)
Precision: (hPa if units not given)
Calibration:
Comments:

Atmospheric CO2

Measured/Frequency: yes, 1hr cycle
Intake Location: unused
Drying Method: unused
Atmospheric CO2 Accuracy: 1 uatm
Atmospheric CO2 Precision: 0.6 uatm

**Aqueous CO2
Equilibrator Design**

System Manufacturer:
Intake Depth: 46cm, with bubble equilibration at 14cm
Intake Location:
Equilibration Type: Bubble Equilibrator
Equilibrator Volume (L): N/A
Headspace Gas Flow Rate (ml/min): ~600 cc/min
Equilibrator Water Flow Rate (L/min): N/A
Equilibrator Vented: Yes
Equilibration Comments:
Drying Method:

**Aqueous CO2
Sensor Details**

Measurement Method: Absolute, non-dispersive infrared (NDIR) gas analyzer
Method details:
Manufacturer: Licor
Model: LI-820
Measured CO2 Values:
Measurement Frequency: 1hr cycle
Aqueous CO2 Accuracy: 2 uatm
Aqueous CO2 Precision: 0.7 uatm
Sensor Calibrations:
Calibration of Calibration Gases: At the beginning of each sample, the instrument self-calibrates using a zero and high standard. The zero standard is generated by cycling a small amount of air through a soda lime chamber. The high standard is from a cylinder of calibrated standard reference gas, 402.67 umol/mol, from ESRL. ESRL standards are traceable to WMO x93 scale with a stated reproducibility of 0.06 micromole/mole. For more information on estimates of accuracy and precision of the MAPCO2 system, see Sutton et al. 2014 (reference below).
Number Non-Zero Gas Standards:
Calibration Gases:
NOAA Earth System Research & Laboratory (ESRL)
Comparison to Other CO2 Analyses:
Comments:
Method Reference:
Sutton, A.J., Sabine, C.L., Maenner-Jones, S., Lawrence-Slavas, N., Meinig, C., Feely, R.A., Mathis, J.T., Musielewicz, S., Bott, R., McLain, P.D., Fought, J., Kozyr, A., 2014b. A high-frequency atmospheric and seawater pCO2 data set from 14 open ocean sites using a moored autonomous system. Earth Sys. Sci. Data, 6, doi: 10.5194/essd-6-353-2014, 353-366.

Equilibrator Temperature Sensor	Location: Manufacturer: Model: Accuracy: (°C if units not given) Precision: (°C if units not given) Calibration: Comments:
Equilibrator Pressure Sensor	Location: Manufacturer: Model: Accuracy: (hPa if units not given) Precision: (hPa if units not given) Calibration: Comments:
Other Sensor	Description: Manufacturer: Maxtec Oxygen Sensor Model: Max-250 Accuracy: 2.0% Full Scale over operating temperature range. 1.0% Full Scale @ constant temperature and pressure Precision: Calibration: Factory calibrated before purchase. Recalibrated to sea level atmospheric air every 7 days Comments:
Other Sensor	Description: Manufacturer: Sensirion Humidity Sensor Model: SHT71 Accuracy: > 0.01% Precision: Calibration: Factory calibrated before purchase. Comments:
Other Sensor	Description: Manufacturer: PMEL duraFET Model: Accuracy: Precision: Calibration: Comments: A PMEL DuraFET was deployed on the saildrone. pH data were recovered however insufficient calibration samples were taken to correct the data.
Additional Information	Suggested QC flag from Data Provider: Additional Comments: <ul style="list-style-type: none"> o All measurements are at sea surface temperature and atmospheric pressure. o During the equilibration cycle, a closed loop of air equilibrates with seawater for 10 minutes. Once the equilibration period is complete, the pump stops and the system opens to the atmosphere allowing the pressure to equilibrate with atmospheric pressure. Measurements are recorded for 30 seconds at 2 hertz and then averaged. o During the air cycle, fresh air is pumped through the detector for 1 minute. Once the pump stops, the system opens to the atmosphere allowing the pressure to equilibrate with atmospheric pressure. Measurements are recorded for 30 seconds at 2 hertz and then averaged. o The gas streams for both the air cycle and equilibrator cycle are partially dried before entering the detector. The values listed as wet xCO₂ generally have relative

humidity levels ranging from 40 to 80 percent. The humidity levels increase over the course of a deployment. o Sampling occurs every 1 hours. The infrared detector is calibrated at the beginning of every sampling period. Averaged data and standard deviations for each measurement are transmitted back daily. o To calculate the dry measurements, the water mole fraction in the Licor detector must be known. A relative humidity sensor is located immediately downstream of the detector. o As part of the QC process, each data set is compared with the Marine Boundary Layer (MBL) data from GlobalView-CO2. As part of the QC process, xCO2 air measurements are compared to the following data sets when available: previous MAPCO2 deployment if overlap on recovery/deployment, following MAPCO2 deployment if overlap on recovery/deployment, and Marine Boundary Layer (MBL) xCO2 air data from GlobalView-CO2. The available comparison data sets are in good agreement with the MAPCO2 air data and no adjustment was made. GLOBALVIEW-CO 2: Cooperative Atmospheric Data Integration Project - Carbon Dioxide. CD-ROM, NOAA ESRL, Boulder, Colorado [Also available on Internet via anonymous FTP to ftp.cmdl.noaa.gov, Path: ccg/co2/GLOBALVIEW], 2010 o During the QC process, an adjustment to the Licor pressure is also made based on each sensor's bias to barometric pressure as measured in the lab. This system has Licor pressure bias of +0.500 applied. Averaged wet xCO2 measurements are post-calibrated using a simple linear regression between original averaged measurements and span coefficients, a method similar to the post-cal established by the underway pCO2 community as described here: Feely, R.A., R. Wanninkhof, H.B. Milburn, C.E. Cosca, M. Stapp, and P.P. Murphy, A new automated underway system for making high precision pCO2 measurements onboard research ships, *Analytica Chim. Acta*, 377, 185-191, 1998. o No data = -999 o These data are made freely available to the public and the scientific community in the belief that their wide dissemination will lead to greater understanding and new scientific insights. The availability of these data does not constitute publication of the data. We rely on the ethics and integrity of the user to assure that PMEL receives fair credit for our work. Please send manuscripts using this data to PMEL for review before they are submitted for publication so we can insure that the quality and limitations of the data are accurately represented.

Citation for this Dataset:

Sutton, A., S. Maenner, S. Musielewicz, R. Bott, and J. Osborne. 2018. High-resolution ocean and atmosphere pCO2 measurements from Autonomous Surface Vehicle ASV_Saildrone1003_Coastal_Tasmania.

Other References for this Dataset:

None